

192T6425

Bar or cable-through CT TCB 44-63 250A/5A Class 0,5 1,5VA

Classification

ETIM - Mechanical characteristics



Strong points

- Compatible accuracy class
- Wide range of ratings and dimensions
- Quick and easy to install

General characteristics

- Accuracy class: 0.2s 0.5 or 1.
- Dielectric quality: 3 kV 50 Hz 1 min.
- Operating frequency: 50 60 Hz.
- Permanent overload: 1.2 In.
- Insulation class: E (120 °C).

Compliance with standards

- IEC 61869-2
- IEC 61439-1

Access to resources (ex: manuals)

Current transformers deliver to the secondary a standard current proportional to the primary current and adapted to the rating of the associated device. They are equipped as standard with removable terminal covers and double terminals allowing the secondary to be short-circuited without any risk.

They are mounted using two screw-on metal brackets or, in certain cases, by a clipon DINrail fastener. The connections are made by screws or by fast-on terminals.

UNSPSC	39121032	
ETIM Class	EC002048	
IGCC	4186	
Commerce		
Effective date	1998-02-11	
Country of origin	DE	
ETIM - Electrical characteristics		
Rated primary current [A]	250	
Rated secondary current [A]	5	
Rated secondary apparent power [VA]	1.5	
Accuracy class	0.5	
Overcurrent limiting factor	FS 5	
Calibrated	No	

With contact protection	No
Height opening [mm]	6363
Width opening [mm]	6363
Opening diameter [mm]	44
Snap mounting	Yes
With copper rail	Yes
Secondary connection	Screw connection

Secondary connection	Screw connection
ETIM - Technical features	
Model	Through-feed current converter
Number of primary inputs	1
Logistics	
GTIN/EAN	3596031092352
Customs number	8504318090
Price unit	PC
147 . 1 . 6 . 1	0.50

GTIN/EAN	3596031092352
Customs number	8504318090
Price unit	PC
Weight of the packing unit	0.58
Length of the packing unit	0.095
Width of the packing unit	0.065
Depth of the packing unit	0.113
Technical Characteristics	

Technical Characteristics	
Model	TCB 44-63
Opening	63x10 - Diam.44
Rated current	250

https://www.socomec.co.uk/engb/reference/192T6425

2024-05-13 21:58:19

Secondary rated current