

41AC7080

Manually operated transfer switch SIRCOVER BY PASS 3+6P 800A front operation



SIRCOVER products are manually operated transfer switches with positive break indication. This combination of three interlocked load break switches provides 3+6 or 4+8 poles for bypass applications.

They provide on-load transfer between two sources for any low voltage power circuit, as well as safety isolation by double breaking per pole. Other applications include source inversion (e.g. to change the direction of a motor) or grounding/earthing.

Strong points

- A complete range
- Stable positions
- On-load switching

General characteristics

- Range from 125A to 1600A.
- Available in 3P or 4P.
- Direct handle or external handle.

Compliance with standards

- IEC 60947-6-1
- IEC 60947-3

Access to resources (ex: manuals)

https://www.socomec.co.uk/en-gb/reference/41AC7080

UNSPSC	39122205
ETIM Class	EC000216
IGCC	5177
Commerce	
Effective date	2014-11-18
Country of origin	FR
ETIM - Electrical characteristics	
Rated permanent current lu [A]	800
Number of poles	3
ETIM - Mechanical characteristics	
Suitable for floor mounting	No
Suitable for front mounting 4-hole	No
Suitable for front mounting centre	No
Suitable for distribution board installation	No
Suitable for intermediate mounting	Yes
Colour control element	Black
Degree of protection (IP), front side	IP20
ETIM - Technical features	
Version as main switch	Yes
Version as maintenance-/service switch	Yes
Version as safety switch	Yes
Version as emergency stop installation	Yes
Version as reversing switch	Yes
Number of switches	3
Motor drive optional	No
Motor drive integrated	No
Voltage release optional	No
Device construction	Built-in device fixed built-in technique
Type of control element	Door coupling rotary drive
Interlockable	Yes
Type of electrical connection of main circuit	Bolt connection
Logistics	
GTIN/EAN	3596032887872
Customs number	8536508090
Price unit	PC
Weight of the packing unit	44.2
Norms	
Conformity to standards	IEC

2024-05-04 23:49:16





Technical Characteristics	
Control operator	Manual Bypass I-0-II
Number of poles	3+6
Rated current	800
Туре	Manual I-I+II-II
Frame size	B6

2024-05-04 23:49:16 2/2