

48503041

Active-energy meter COUNTIS E05 Direct 40A with M-BUS com.



Strong points

- Compact
- Output (pulses)
- B+D module MID-certified

General characteristics

- Compact dimensions.
- Measurement accuracy: 1%.
- Displayed on backlit screen.
- Multi-measurement available on display.

Compliance with standards

- IEC 62053-21 Class 1
- IEC 62053-23 Class 2
- IEC 62053-31
- IEC 62052-11
- EN 50470-1
- EN 50470-3

Access to resources (ex: manuals)

2024-05-04 15:24:52



https://www.socomec.co.uk/engb/reference/48503041

COUNTIS E0x devices are modular electrical energy meters, they display kWh and kVArh readings and other measurements on the backlit LCD screen. These devices allow a direct connection up to 40 A.

COUNTIS E02, E04 and E06 units are MID-certified.

NSPSC	41113708
TIM Class	EC001506
GCC	6341
Commerce	
Effective date	2016-04-12
Country of origin	IT
ETIM - Electrical characteristics	
Nominal current (In) [A]	40
Max. current (Imax) [A]	40
Nominal voltage (Un) N-L [V]	184276
Nominal voltage (Un) L-L [V]	320480
Frequency [Hz]	5060
Accuracy class	В
Pole type	Single phase
Energy type	Effective power and blind power
Suitable for	Purchase/supply
Fariff type	Two-tariff
Fariff control	External
Measurement type load profile	No
Calibrated	Yes
Pulse output	Electrical
Pulse type	S0
Pulse rate [Imp/kWh (kvarh)]	1010
ETIM - Mechanical characteristics	
Escapement mechanism	No
Mounting method	DRA (DIN-rail adapter)
Nidth in number of modular spacings	4
Nith lock code	No
Degree of protection (IP)	IP20
ETIM - Technical features	
Type of meter	Electronic
Model	Direct measurement
Approval	Domestic
Гуре of indication	Digital
Γype of interface	M-bus (wired)
EEC40 signature	No
Logistics	
GTIN/EAN	3596032942366
Customs number	9028301100
Price unit	PC
Weight of the packing unit	0.1

2/024-05-04 15:24:52



COUNTIS E05 1PH 40A M-BUS

Width of the packing unit	0.095	
Depth of the packing unit	0.107	
Norms		
Conformity to standards	IEC	
Technical Characteristics		
Application	Metering	
Communication ports	M-BUS	
Model	E05	
Туре	1PH up to 40A	

2024-05-04 15:24:52 3/3