

IEC**IECEE**

Ref. Certif. No.

CN74185-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

SWITCH DISCONNECTOR

Name and address of the applicant

SOCOMECS.A.S
1, RUE DE WESTHOUSE 67230 BENFELD CEDEX
FRANCE

Name and address of the manufacturer

SOCOMECS.A.S
1, RUE DE WESTHOUSE 67230 BENFELD CEDEX
FRANCE

Name and address of the factory

SOCOMECS.A.S
1,Rue De Westhouse 67230 Benfeld Cedex France*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

Ui:800V;Uimp:8kV;Ith:125A;Ue:AC415V;Ie:125A;Utilization category:AC-21A;Icw:2.5kA/1s;Icm(peak):3.55kA;Iq:10kA;3P, 4P.

Trademark (if any)

SOCOMECS

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

SIRCO VM1 125A;

Additional information (if necessary may also be reported on page 2)

Original CB certificate No. is CN74185, dated 2025-11-10. The issuance of the M1 certificate is to add Iq current.

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2020;IEC 60947-3:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2025CQC-124819-M1

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Dec.05,2025

Signature:

Xie ZhaoXu