

IEC

IECEE



TM

Ref. Certif. No.

CN65936

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Transfer Switching Equipment

Name and address of the applicant

SOCOMECS.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOMECS.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

*Note: When more than one factory, please report on page 2*SOCOMECS.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

Ratings and principal characteristics

See the Appendix

Trademark (if any)

SOCOMECS

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

SIRCOVER AC 800A, SIRCOVER AC 1000A, SIRCOVER
AC 1250A;Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity with

IEC 60947-6-1:2021;IEC 60947-1:2020

As shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2024CQC-113617

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: May.29,2024

Signature:

谢肇煦

Xie ZhaoXu



SIRCOVER AC 800A, SIRCOVER AC 1000A, SIRCOVER AC 1250A

Ui:1000V;

Uimp:12kV;

Ith:800A,1000A,1250A;

Ue:AC415V;

Ie:AC-33B:800A(SIRCOVER AC800A),1000A(SIRCOVER AC 1000A),

AC-32B:1250A(SIRCOVER AC 1250A);

Utilization category:AC-33B,AC-32B;

Icw:20kA/60ms(SIRCOVER AC 800A,SIRCOVER AC 1000A), 25kA/60ms(SIRCOVER AC 1250A);

Icm:40kA(SIRCOVER AC 800A,SIRCOVER AC 1000A), 52.5kA(SIRCOVER AC 1250A);

Class of equipment: PC;

Method of controlling: MTSE;

Number of poles: 3P,4P

Page 1 of 1

Additional information (if necessary)

Date:

May.29,2024

Signature:

谢肇煦
Xie ZhaoXu