



Ref. Certif. No.

CN55350

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

SWITCH DISCONNECTOR

Name and address of the applicant

SOCOMEC S.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOMEC S.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

Note: When more than one factory, please report on page 2

SOCIETE TIMELEC SARL
ZONE INDUSTRIELLE CHEBEDA ROUTE DE FOUCHANA
NAASSEN 1135 NAASSEN GOUVERNORAT DE BEN AROUS,
Tunisia

Ratings and principal characteristics

Uimp: 8kV;Ui: 800V;lth: 125A(SIRCO 125A),160A(SIRCO 160A),200A(SIRCO CD 200A);
Ue: AC415V;Ie: 125A(SIRCO 125A),160A(SIRCO 160A),200A(SIRCO CD 200A);
Icw:7kA/1s;Icm(Peak):11.9kA; Iq: 50kA,100kA;Utilization category: AC-23A,AC-22A;Number
of poles:3P,4P;Rated frequency :50/60Hz

Trademark / Brand (if any)

SOCOMEC

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

SIRCO 125A,SIRCO 160A,SIRCO CD 200A;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-3:2020 in conjunction with IEC 60947-1:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2021CQC-099869

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Dec.21,2021

Signature:

谢肇煦
Xie ZhaoXu

CB 0066097