



Ref. Certif. No.

CN55344

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Switch-disconnectors

Name and address of the applicant

SOCOMECS.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOMECS.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

Note: When more than one factory, please report on page 2

SOCIETE TIMELEC SARL

ZONE INDUSTRIELLE CHEBEDA ROUTE DE FOUCHANA  
NAASSEN 1135 NAASSEN GOUVERNORATDE BEN AROUS,  
Tunisia☒ Additional information on page 2

Ratings and principal characteristics

Uimp: 8kV;Ui: 800V;Ith: 200A(SIRCO 200A),250A(SIRCO 250A),500A(SIRCO CD 500A);Uc:  
AC415V;Ie: 200A(SIRCO 200A),250A(SIRCO 250A),500A(SIRCO CD  
500A);Icw:9kA/1s;Icm(Peak):15.3kA; Iq: 50kA(SIRCO 200A,SIRCO 250A);Utilization  
category: AC-23A;Number of poles:3P,4P;Rated frequency :50/60Hz

Trademark / Brand (if any)

SOCOMECS

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

SIRCO 200A, SIRCO 250A, SIRCO CD 500A

Additional information (if necessary may also be  
reported on page 2)A sample of the product was tested and found  
to be in conformity with

IEC 60947-3:2020 in conjunction with IEC 60947-1:2020

As shown in the Test Report Ref. No. which  
forms part of this Certificate

00901-CB2021CQC-099875

This CB Test Certificate is issued by the National Certification Body

## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Dec.21,2021

Signature:

谢肇旭

Xie ZhaoXu

CB 0066108

| Name of the factory | Address of the factory                         |
|---------------------|------------------------------------------------|
| 1.SOCOMEK S.A.S     | 1, Rue De Westhouse 67230 Benfeld Cedex France |

Additional information (if necessary)

Date: Dec.21,2021

Signature:

  
Xie ZhaoXu