



Ref. Certif. No.

CN55681

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

SWITCH DISCONNECTOR

Name and address of the applicant

SOCOMECS.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOMECS.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

SOCOMECS.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Uimp:12kV; Ui:1000V; Ith:4000A(SIRCO 4000A),5000A(SIRCO 5000A); Ue:AC415V;
Ie:4000A(SIRCO 4000A),5000A(SIRCO 5000A); Icw:75kA/1s; Icm(Peak):165kA; Utilization
category: AC-21B; Number of poles:3P,4P;Rated frequency :50/60Hz

Trademark / Brand (if any)

SOCOMECS

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

SIRCO 4000A, SIRCO 5000A

Additional information (if necessary may also be
reported on page 2)

IEC 60947-1:2020;IEC 60947-3:2020

A sample of the product was tested and found
to be in conformity withAs shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2021CQC-099882

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Dec.28,2021

Signature:

谢肇煦

Xie ZhaoXu

CB 0066200