

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

SWITCH DISCONNECTOR

Name and address of the applicant

SOCOMECS.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOMECS.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

Zhejiang Socomec Co.,Ltd.

(Zhejiang KEDU Electric Manufacture Co.,Ltd.) Heshenqiao Industrial
Zone, Puqi Town, Yueqing, Zhejiang Province, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

☒ Additional information on page 2Uimp: 8kV;Ui: 800V;Ith: 16A,20A,25A,32A,40A,63A; Ue: AC415V;Ie: AC-23A:16A(SIRCO M16),20A(SIRCO
M20),25A(SIRCO M25),32A(SIRCO M32),40A(SIRCO M40),40A(SIRCO M CD63); AC-22A:63A(SIRCO M
CD63);Utilization category: AC-23A,AC-22A; Number of poles:3P,4P(with additional pole); Icw: 1.26kA/1s;
Icm(Peak value): 1.8kA Rated frequency :50/60Hz

Trademark / Brand (if any)

SOCOMECS

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

SIRCO M16, SIRCO M20, SIRCO M25, SIRCO M32, SIRCO M40,
SIRCO M CD63;Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity with

IEC 60947-1:2020;IEC 60947-3:2020

As shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2021CQC-099878-A1

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE


Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Jan.04,2022

Signature:


Xie ZhaoXu

CB 0066301

Name of the factory	Address of the factory
1.SOCIETE TIMELEC SARL	ZONE INDUSTRIELLE CHEBEDA ROUTE DE FOUCHANA NAASSEN 1135 NAASSEN GOUVERNORATDE BEN AROUS, Tunisia

Additional information (if necessary)

Date: Jan.04,2022

Signature:


Xie ZhaoXu