

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Switch-disconnectors

Name and address of the applicant

SOCOMECS.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOMECS.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

Zhejiang Socomec Co.,Ltd.

(Zhejiang KEDU Electric Manufacture Co.,Ltd.) Heshenqiao Industrial
Zone, Puqi Town, Yueqing, Zhejiang Province, P.R.China*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

Uimp:8kV; Ui:800V; Ue:AC415V; Ith:32A,63A,100A,125A;
Ie:32A,63A,100A,125A; Icw:2.75kA/1s; Icm(peak):3.9kA; AC-23A; 3P,4P with
additional Pole; 50/60Hz

Trademark / Brand (if any)

SOCOMECS

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

SIRCO M 32, SIRCO M 63, SIRCO M 100, SIRCO M 125

Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity with

IEC 60947-3:2020 in conjunction with IEC 60947-1:2020

As shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2021CQC-099880

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE


Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Dec.21,2021

Signature:



Xie ZhaoXu