

IEC

IECEE

®

TM

Ref. Certif. No.

CN55582-A1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

SWITCH DISCONNECTOR

Name and address of the applicant

SOCOMEK S.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOMEK S.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

Zhejiang Socomek Co.,Ltd.

(Zhejiang KEDU Electric Manufacture Co.,Ltd.) Heshenqiao Industrial
Zone, Puqi Town, Yueqing, Zhejiang Province, P.R.China

Note: When more than one factory, please report on page 2

☒ Additional information on page 2

Ratings and principal characteristics

Uimp: 8kV;Ui: 800V;Ith: 63A, 80A,100A;Ue: AC415V;Ie: 63A, 80A,100A; Utilization
category: AC-23A(63A,80A);AC-22A(100A); Number of poles:3P, 4P(with additional pole);
Icw: 1.5kA/1s;Icm(Peak value): 2.1kARated frequency :50/60Hz

Trademark / Brand (if any)

SOCOMEK

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

SIRCO M63, SIRCO M80,SIRCO M CD100;

Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity with

IEC 60947-1:2020;IEC 60947-3:2020

As shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2021CQC-099881-A1

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Jan.04,2022

Signature:

谢肇煦

Xie ZhaoXu

CB 0066302

Name of the factory	Address of the factory
1.SOCIETE TIMELEC SARL	ZONE INDUSTRIELLE CHEBEDA ROUTE DE FOUCHANA NAASSEN 1135 NAASSEN GOUVERNORATDE BEN AROUS, Tunisia

Additional information (if necessary)

Date: Jan.04,2022

Signature:


Xie ZhaoXu